



Series 500600SS4

PVC Bell Protection System

INSTALLATION INSTRUCTIONS

The Series 5000 MEGA-STOP Bell Stop is designed to prevent “over-belling” or over insertion of the spigot or plain end of the pipe into a push-on pipe bell, while allowing the pipe to properly expand or contract due to thermal differences. The Series 500 MEGA-STOP is used on AWWA C900 PVC Pipe, and consists of one split serrated MEGA-STOP Bell Stop Ring and one Expansion Retention Spring (ERS).

1. Place the Expansion Retention Spring (ERS) on the spigot and position it so that the manufacture’s stop mark/assembly mark is visible through the front notches. If the mark is missing due to fading or a cut pipe, place a mark at the pipe manufacture’s recommended measurement, chamfering the pipe may also be recommended by the pipe manufacturer. (The ERS is bi-directional. Once placed on pipe the notches nearest the pipe chamfer are the front notches.)
2. Disassemble the halves of the MEGA-STOP and reassemble them on the spigot against the back side of the ERS with the extensions of the MEGA-STOP inside of the notches on the back side of the ERS. Tighten the side bolts evenly to a torque of 70 ft-lbs.
3. Assemble the pipe joint in accordance with the PVC pipe manufacturer’s installation instructions.



CONTENTS

- 1 - 6 inch Series 5000 Split Restraint
- 1 - 6 inch Expansion Retention Spring (ERS)

For use on water or wastewater pipelines subject to hydrostatic pressure and tested in accordance with either AWWA C600 or ASTM D2774

APPROXIMATE SHIPPING WEIGHT: 6.4 LBS.

0118-A

©EBAA IRON, Inc.



Series 500600SS4
PVC Bell Protection System



EBAA Iron Sales, Inc.
P.O. Box 857, Eastland, TX 76448
Tel:(254) 629-1731
Fax:(254) 629-8931
(800) 433-1716 within US and Canada
contact@ebaa.com
www.ebaa.com

Made in the USA