

Connections™

EBAA IRON

TECHNICAL DATA FOR THE WATER & WASTEWATER PROFESSIONAL

PD - 1

JOINT RESTRAINT vs. THRUST BLOCKS

The question often arises “Can you really eliminate thrust blocks using joint restraint?” This bulletin will provide you with the information needed for you to realize the answer to that question is “yes”. For many years, thrust blocks have been successfully used in distribution systems all over the world. Thrust blocks, however, are not without limitations.

THRUST BLOCKS UNCOVERED

It has been argued that thrust blocks are the cheapest form of pipeline restraint. When all of the costs such as labor, forming time and waiting for concrete to be poured and cure is added to the price of the concrete, the thrust block is not as cheap as originally thought.

A thrust block prevents separation of joints and pipe movement by transferring the resultant thrust force at a bend to the undisturbed soil behind the thrust block. The bearing strength of the soil is expressed in pounds per square foot. Therefore, the area behind the thrust block must engage enough soil area to resist the resultant thrust force at a change in direction. The thrust block design is commonly determined by the equation $A_b = S_f * T / S_b$. Where A_b is the required bearing area of the thrust block, S_f is the safety factor, T is the resultant thrust force (see Connections Bulletin PD-2), and S_b is the bearing strength of the soil. As an example, for a 90-degree bend in a 12-inch ductile iron pipeline at 150 psi in a soil with a bearing strength of 2000 psf and a safety factor of 1.5:1 the required thrust block bearing area is almost 22 square feet—roughly 6.6 feet by 3.3 feet.

A properly designed thrust block involves much more than “dumping” a load of concrete behind a bend. The design involves consideration of undisturbed soil, soil bearing strength, test pressure, pipe size, fitting configuration, and trench depth to determine the bearing area of the thrust block. It is then a matter for the installer to form up and pour the proper block. Care needs to be taken to prevent the concrete from covering the joints at fittings, the weep holes in hydrants, and operating mechanisms of valves. Once the thrust block has been properly designed and properly formed, a concrete truck must be called to the site to pour the concrete. Now the waiting begins. Only after the concrete has

cured can the pipeline be charged with water and tested. This procedure addresses horizontal fittings. When complicated bend combinations, vertical downbends, parallel lines, dead ends, and future excavation possibilities become involved, the use of thrust blocks become very problematic. This report does not begin to explore the combinations involved with thrust blocks in locations with poor soil conditions.

JOINT RESTRAINT ADVANTAGES

A properly designed, restrained pipeline uses the bearing strength and frictional resistance of the soil, essentially, to turn the pipeline into a thrust block. The same basic parameters required to determine the size of a thrust block are used to determine the amount of pipe that must be restrained to resist thrust forces underground. These parameters are pipe size, pipe type, test pressure, fitting type, trench type, depth of bury, soil type, and safety factor. With this information and the various design equations, it is possible to quickly and simply calculate the length of piping that must be restrained.

With over twenty years experience, it is now a well-established fact that not all joints have to be restrained in order to have a safe system. At the beginning of restrained joint pipeline design, the equations used to determine the length of pipe to be restrained were the subject of much speculation and theory. The equations and soil values used by EBAA are based on actual testing and evaluation. In 1980 and 1981 the Ductile Iron Pipe Research Association engaged in a study to evaluate the various design equations being used at the time. Full-scale tests were performed on a twelve-inch ductile iron pipe and forty-five and ninety degree bends. The results of these tests were used to modify an existing equation and implement soil property modifiers for various trench conditions. These equations have been successfully used for many years. All of the soil properties for the soil to pipe interface were, however, assumed based on tests of pilings to determine the soil friction values for steel. In 1989 EBAA Iron embarked on a soil study to determine actual soil properties on ductile iron, ductile iron wrapped with polyethylene, and PVC pipe surfaces. The combination of the conservative, thrust restraint equations and updated soil information is provided in the design handbooks and computer software available from EBAA free of charge.

Using joint restraints opens possibilities that are not available with thrust blocks. When construction is required in congested underground areas it is next to impossible to pour thrust blocks without interfering with other utilities. Also, the use of thrust blocks in congested areas poses a particular problem when construction or maintenance of a different utility occurs in close proximity to the thrust block. If the soil behind the thrust block is disturbed or if the block is thought to be a rock that needs to be removed, the pipeline fitting can be separated from the line resulting in loss of water, property damage, delays, and other costly side effects. Restrained pipelines can be installed in congested areas without affecting or being affected by other utilities or future construction. Because the bearing area of a restrained pipeline is not concentrated in a small area, excavations in close proximity do not pose the danger that could be experienced with thrust blocks.

Continuing with the previous 90-degree bend example but utilizing restrained length design instead of thrust blocks, a comparable 12-inch ductile iron pipeline with a 3 ft depth of bury in a silty-sand with a type 5 trench compaction the restrained length requirement is 28 feet. That is two restraints at the fitting and one restraint on the first line joint back on each leg of the fitting for a total of four restraints. (See Connections Bulletin PD-02.)

JOINT SELECTION

Thrust blocks are commonly used with push-on fittings. This type of fitting can be difficult to install and, when pipe has to be cut in the field, extra time and effort are required to bevel the end of the pipe to enable insertion of the spigot into the fitting bell. This requires powered equipment or special rigging tools. Taking a push-on joint apart can be even more difficult. The mechanical joint, on the other hand, is very adaptable to changes and fabrication in the field. Pipe cut in the field is easily inserted into the MJ bell and the joint is made by tightening some bolts. Disassembling a mechanical joint to make changes or adjustments is simple and straightforward.

Very little extra effort is required to restrain a mechanical joint fitting after the t-bolts have been tightened. EBAA mechanical joint restraint products utilize accepted assembly procedures to seal the joint, then the simple tightening of wedges to restrain the joint. This requires no special tooling or rigging and can be performed by one man with hand or power tools. Complex fitting configurations can be fabricated outside of the trench and lowered into place for final connections. Additionally, the use of joint restraint products in the design and construction of parallel pipelines eliminates the problem associated with one thrust block being required to encompass another fitting. Once the line is restrained and buried, the line can be tested immediately. This hastens the construction process and prevents the need for trenches to be left open for long periods of time. This cannot be done with unrestrained joints that require thrust blocks.

SUMMARY

Can you really eliminate thrust blocks using joint restraint? Based on years of experience, the answer is "yes". The use of the EBAA Iron mechanical joint restraint products and proven design procedures allows for reliable installations that effectively eliminate the need for thrust blocks. The use of the mechanical joint enables field adaptability that is not available with all joint restraint products. Pipe can be cut in the field and fittings assembled with simple procedures that allow for the prompt acquisition of materials and completion of construction. All of this combines to provide you with a safe and proven piping system without depleting your resources.

References:

Ductile Iron Pipe Thrust Restraint Design Handbook, EBAA Iron Sales, Inc., 1993



This is one in a series of Connections reports addressing design and application subjects. If you would like additional copies of other reports or a listing of available reports contact your EBAA Iron representative or call EBAA Iron Sales at 800.433.1716 or fax 254.629.8931. EBAA's engineering group can be reached at 800.633.9190 or fax 254.629.2079. Copyright© 1995 Ebaa Iron Sales, Inc.

ISSUE: 0119-B

P.O. BOX 857 • EASTLAND, TEXAS 76448 USA • PHONE 254.629.1731 • TELEFAX 254.629.8931 • TOLL-FREE 800.433.1716 • WWW.EBAA.COM • CONTACT@EBAA.COM